

## KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

was issued to

**HVC Technology And Investment JSC**

Hanoi, Vietnam

for the test object:

low-voltage

**power switchgear and controlgear assembly**

Type: MSB - 6300 A

Rating: 400 V – 6300 A – 65 kA - 50 Hz

manufactured by

**HVC Hung Yen Co., Ltd**

Hung Yen Province, Vietnam

The test object has successfully passed the required type tests of

**IEC 61439-2, IEC 61439-1**

subclause 10.2 (Strength of materials and parts),  
subclause 10.3 (Degree of protection of assemblies (IP Code)),  
subclause 10.4 (Clearances and creepage distances),  
subclause 10.5 (Protection against electric shock and integrity of protective circuits),  
subclause 10.9 (Dielectric properties),  
subclause 10.10 (Temperature-rise),  
subclause 10.11 (Short-circuit withstand strength),  
subclause 10.12 (Electromagnetic compatibility)

The test results are recorded in Certificate No.

**5131-23**

This Certificate was first issued on 2 October 2023.

Zkušebnictví, a.s.



Robert Jech

Operational Manager

